



REQUIRED SWIMMING POOL INSPECTIONS

Inspection #1 – Prior to backfill

1. Grounding of all metal for pool walls
2. Grounding of light niche and any below-grade metal
3. Inspection of underground conduits

Inspection #2 – Prior to concrete deck placement

1. Grounding of all equipment support brackets (ladder, diving board, steps, coping, etc.)
2. Inspection of light niche interior bond prior to filling pool

Final Inspection

1. Check all electrical equipment
2. Fence installation
3. All access in fence (self-closing and latching)
4. All doors with direct access require alarms or approved self-closing and latching devices