



NOT TO SCALE

- NOTES:
1. CONCRETE TO BE 3,000 PSI.
 2. PIPE SHALL BE DUCTILE IRON PIPE.
 3. FOR CROSSINGS GREATER THAN 15 FEET IN WIDTH, THE FOLLOWING SHALL APPLY:
 - 3.1 GATE VALVES SHALL BE INSTALLED ON BOTH SIDES OF THE CROSSING FOR TESTING & REPAIR. THE VALVES SHALL BE EASILY ACCESSIBLE AND NOT SUBJECT TO FLOODING.
 - 3.2 A BLOW-OFF SHALL BE PROVIDED ON THE SIDE OPPOSITE THE SUPPLY SERVICE, IN ACCORDANCE WITH DETAIL 4.12.



REVISIONS		
DATE	BY	DESCRIPTION
5/28/22	BGM	CHANGE FONT, TITLE BLOCK, NUMBER

WATER LINE CROSSING
BENEATH STREAMBED

DWG. NO.
4.18