


NOTE: WHEN 10' HORIZONTAL DISTANCE CANNOT BE MAINTAINED, 18" VERTICAL SEPARATION REQUIRED WITH SANITARY SEWER BENEATH WATER LINE.

PLAN VIEW



PROFILE VIEW

NOT TO SCALE



REVISIONS		
DATE	BY	DESCRIPTION
5/26/22	BGM	CHANGE FONT, TITLE BLOCK

WATER AND SEWER
SEPARATION

DWG. NO.

4.05