



- NOTES:
1. THE THRUST BLOCKING MUST NOT COVER THE HYDRANT DRAIN HOLE
 2. FIRE HYDRANT COLOR TO BE RED WITH WHITE TOP AND CAPS COLOR CODED TO MATCH FLOW. SEE TABLE
 3. HYDRANT DRAINS SHALL NOT BE CONNECTED WITHIN 10 FT OF SEWER SYSTEMS.
 4. HYDRANT TO BE PLACED WITH PUMPER NOZZLE FACING THE STREET UNLESS OTHERWISE NOTED.

NOT TO SCALE

CAP COLOR CODING	
FLOW RATE	COLOR
500 GPM - 999 GPM	SAFETY ORANGE
1000 GPM - 1499 GPM	SAFETY GREEN
> 1500 GPM	SAFETY BLUE



REVISIONS

DATE	BY	DESCRIPTION
9/29/05	CKC	ADDED COLOR CODING
9/29/05	CKC	CHANGED HYDRANT TYPE
5/28/22	BGM	CHANGE FONT, TITLE BLOCK
5/28/24	BGM	ADDED STORZ CONNECTION

FIRE HYDRANT STANDARD DETAIL

DWG. NO.

4.01