



NOTES:

1. RESIDENTIAL DRIVEWAYS TO BE 12' TO 18' IN WIDTH.
2. COMMERCIAL DRIVEWAYS TO BE A MAXIMUM OF 35 FEET WIDE.
3. SIDEWALK TO BE MIN. 5" THICK WITH MEDIUM BROOM FINISH.
4. DRIVEWAY TO BE MIN. 6" THICK WITH LIGHT BROOM FINISH.
5. ALL CONCRETE TO BE 4000 PSI.
6. CURB AND GUTTER TO BE SAW CUT AND REMOVED TO THE NEAREST JOINT ON EITHER SIDE OF DRIVEWAY.
7. ALL DRIVEWAYS AND SIDEWALK MUST BE INSPECTED PRIOR TO ISSUANCE OF A CERTIFICATE OF OCCUPANCY.
8. IN ANY SITUATIONS THAT ARE NOT COVERED BY DETAIL 7.10, 7.11, OR 7.12, A DETAIL WILL BE PROVIDED BY THE ENGINEERING DEPARTMENT.



REVISIONS

DATE	BY	DESCRIPTION
6/30/05	CKC	CREATED
8/25/05	TCZ	MISC.
1/5/06	TCZ	ADDED MAXIMUM GRADES
6/21/23	BGM	CHANGE FONT, TITLE BLOCK

DRIVEWAY APRON WITH  
SIDEWALK, GRASS  
STRIP <7' - 4 3/4"

DWG. NO.

7.11